



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

July 21, 2008

BRAUN CONCRETE & EXCAVATING, INC.
TOM REIGEL
609 W SOUTH ST
LOYAL WI 54446

Re: Description: SEWAGE TANK, SITE CONSTRUCTED
Manufacturer: BRAUN CONCRETE & EXCAVATING, INC.
Product Name: HOLDING TANK
Model Number(s): MARAWOOD 5000
(90" L.L., 53.21 GAL/IN., 36" MAX. BURY DEPTH, 4789 TOTAL GALLONS)
Product File No: 20080326

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.

This approval is valid until the end of AUGUST 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on 5/8/2008 under product file number 20040440. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040440.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov